

ADDENDUM No. 1
TO THE
CONTRACT DOCUMENTS FOR CONSTRUCTION OF
STORM REHABILITATION BROOKLYN AVE.
PROJECT #21PW14

THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS DATED
May 10, 2021, TO THE SAME EXTENT AS THOUGH IT WERE ORIGINALLY INCLUDED
THEREIN.

ISSUED THIS 27th DAY OF May, 2021.

CITY OF ROSEBURG
PUBLIC WORKS DEPARTMENT
900 SE DOUGLAS AVENUE
ROSEBURG, OREGON 97470
(541) 492-6730

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May 10, 2021 as noted below. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Bidding and Contract Documents:

Advertisement for Bid: REVISE the second paragraph, as shown below

Bids are due by 2:00 p.m. on **Thursday, June 3, 2021**

All bids will be opened at 2:00 p.m.

Additional forms disclosing first tier subcontractors are due by 4:00 p.m.

No bids shall be received after this date and time.

Invitation to Bid: REVISE the first sentence of the first paragraph as shown below

The City of Roseburg will receive sealed bids or bids submitted via email marked "Bid for Storm Rehabilitation Brooklyn Ave., Project No. 21PW14" until the hour of 2:00 p.m. on **Thursday, June 3, 2021**, at which time they will be publicly opened and read in person or virtually.

Clarifying Information:

Question: Is a full closure with detour possible for Vine St between Church and Brooklyn possible?

A: Yes, detour route and temporary traffic control plan will be required. Local access within the closure area shall be permitted.

Question: Will ODOT allow for excavation of manhole 7, with it being in the OR99 ROW? If so, are there any specific restoration and paving requirements?

A: OR99, (Stephens Street) is City of Roseburg ROW and jurisdiction, excavation of manhole #7 will be permitted as necessary. Pavement restoration in Stephens Street will be a minimum of 7" thick, all other locations 4" thick.

Question: Are there any lane closure restrictions for work performed in the ODOT ROW on OR99?

A: OR99, (Stephens Street) is City of Roseburg ROW and jurisdiction. Single

lane closure may be permitted as needed.

Question: Can the construction timeline be extended to summer 2022?

A: Contract allows 120 days for completion, anticipate Notice to Proceed to be issued late July 2021.

Question: Can you provide a sanitary sewer system map to determine locations for cure water discharge?

A: Sanitary sewer is provided by Roseburg Urban Sanitary Authority (R.U.S.A.). Use of their utility shall be approved by RUSA prior to use.

Question: Is it possible to delay the bid 1-2 days to allow for extra prep time given the holiday weekend?

A: See response to this question below.

Question: There is a large protrusion in the pipe wall @ 36' between manholes 5 & 6. How is this defect to be repaired prior to lining? Will the City perform and point repair at this location?


A: Safeway has been notified of the damaged caused by their lateral connection. Safeway is working on getting the damaged repaired prior to lining.

SPECIFICATIONS

00416.21 - SUBMITTALS: Add the following paragraph:

(o) Mass balance calculations of Geopolymer Mortar required to provide approved design thickness for each section of pipe between manholes.

END OF ADDENDUM NO. 1



Ryan Herinckx
Project Manager